

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
PV 60141112

Blatt *Sheet*
0006

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*
0001--21290518 005

Ausstellungsdatum
08.12.2021

Date of Issue
(day/mo/yr)


Genehmigungsinhaber *License Holder*

Vikram Solar Limited
The Chambers, 8th Floor
1865, Rajdanga Main Road
Kolkata 700107
India

Fertigungsstätte *Manufacturing Plant*

Refer to latest revision
of the annex list of factories

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV Module

Types with mono half cut bifacial cells:
PREXOS VSM DHT.72.AAA.05
(AAA = 430 - 535 in steps of 1, 144 cells)
PREXOS VSM DHT.60.AAA.05
(AAA = 355 - 435 in steps of 1, 120 cells)
AAA represents output power in Wp

Remarks:

Class II acc. to IEC 61140
Max. System voltage: 1500 VDC (Voc at STC)
Additional requirements for bifacial modules tested
according 2 PFG 2665/06.18 and 2 PFG 2645/11.18.
Max. Design Load (downward/upward): 3600/1600 Pa
with safety factor 1.5
Fire Class C per UL 1703 (per UL 790 modified)
Additional applicable test standards see page 2.

Conditions:

The product test is voluntarily according to technical
regulations. Any change of the design, materials, components
or processing may require the repetition of some of the
qualification tests in order to retain type approval.

Validity: 29 July 2024

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

