

Certificate



Certificate no.

US 72302348 04

License Holder:

Vikram Solar Ltd
The Chambers, 8th Floor
1865 Rajdanga Main Road
Kolkata, West Bengal 700107
India

Manufacturing Plant:

Vikram Solar Ltd. (Unit II)
Falta, District: South 24-Parganas
SEC-II, Falta, Special Economic Zone
P. S.: Ramnagar, P. O.: Falta S.O
West Bengal 743504
India

Test report no.: USA- IN23JU5K 003

Client Reference: Mr. Gopal Kumar

Tested to:

- UL 61730-1:2022
- UL 61730-2:2022
- UL 61215-1:2021
- UL 61215-1-1:2021
- UL 61215-2:2021

Certified Product: Photovoltaic Module

License Fee - Units

as pages 1 and 2

- Use of additional components and materials

- Type extension:

Type with Topcon Bifacial Half cut 91x182mm (M10) cells:

HYPERMOL VSM DH.72.AAA.05 (AAA=565-580 in steps of 1, 144) 1

HYPERMOL VSM DH.60.AAA.05 (AAA=450-460 in steps of 1, 120)

HYPERMOL VSM DH.54.AAA.05 (AAA=400-425 in steps of 1, 108)

Type with Mono Bifacial Half cut 91x182mm (M10) cells:

PARADEA VSM DH.78.AAA.05 (AAA=585-605 in steps of 1, 156)

xxx represent output power in Wp

Max. System voltage: 1500 V DC

Second manufacturing plant: see page 2 (2279225)

1

Appendix: 1, 1-28

Licensed Test mark:

Date of Issue

(day/mo/yr)

16/04/2024

